



MARYLAND DEPARTMENT OF THE ENVIRONMENT
2500 Broening Highway • Baltimore, Maryland 21224
(410) 631-3000

Parris N. Glendening
Governor

Jane T. Nishida
Secretary

September 19, 1995

Mr. William Meyers
3420 Dillon Street
Baltimore, MD 21224

RE: Lead Abatement Project
3200 Dillon Street
Baltimore, MD 21224

Dear Mr. Meyers:

The Maryland Department of the Environment (MDE) conducted inspections of the above referenced lead abatement project on July 13 and August 31, 1995.

The inspections included dust wipe sampling and laboratory analysis. All samples contained lead levels below the clearance standards. Based on the results of laboratory analysis and the visual inspections, the lead abatement project is complete and complies with the State abatement standards set forth in Section 26.02.07.12K of the Code of Maryland Regulations ("COMAR"). This statement of completion does not preclude the Department from taking any future enforcement action with respect to the subject property and does not provide certification that the building is either lead-free or lead safe.

Please contact me at (410) 631-3825 if you have any questions.

Sincerely,

John C. O'Brien
Inspector
Lead Compliance Section

JOB:job

Enclosures

cc: Mr. Alvin Bowles
Mr. Richard Collins



Date: 07/19/95
Time: 09:04

FINAL REPORT

Client:

Submitter:

HOUSE AT 3200 , DILLOW ST.
BALTIMORE MD 212240000

DEPT OF ENVIRON LEAD & SOIL
2500 BROENING HIGHWAY
BALTIMORE, MD 21224

Client Number: 0000537960001
Date of Birth:
Sex: ? Race: 0

Social Security Number: 000-00-0000
Case Number:
Date Received: 07/14/95

=====

* * * Dust * * *

Dust Clearance Limits: Floor 200 ug/sq ft
Window Sill 500 ug/sq ft
Window Well 800 ug/sq ft

Specimen: 27033 Result for 07/14/95 15:43 Units
Lead(Pb) in Dust

below detection limit

Location: main room Area in Inches
Surface: field blank (L x W): 12 x 12
Submitter's sample number: 101 Case number: 95-30-066
Sample collected by: J. O'Brien

Specimen: 27034 Result for 07/14/95 15:43 Units
Lead(Pb) in Dust 221 ug/sq ft

Location: stairwell Area in Inches
Surface: floor (L x W): 12 x 12
Submitter's sample number: 102 Case number: 95-30-066
Sample collected by: J. O'Brien

Specimen: 27035 Result for 07/14/95 15:43 Units
Lead(Pb) in Dust

Below detection limit

Location: main room Area in Inches
Surface: floor (L x W): 12 x 12
Submitter's sample number: 103 Case number: 95-30-066
Sample collected by: J. O'Brien

Specimen: 27036 Result for 07/14/95 15:43 Units
Lead(Pb) in Dust 14 ug/sq ft

Continued on next page

Client: HOUSE AT 3200 , DILLOW ST. Client Number: 0000537960001
Submitter: DEPT OF ENVIFON LEAD & SOIL

Specimen: 27036 Result for 07/14/95 15:43 Units

Continued from previous page

Location: hallway	Area in Inches
Surface: sill	(L X W): 47 x 2.75
Submitter's sample number: 104	Case number: 95-30-066
Sample collected by: J. O'Brien	

Specimen: 27037 Result for 07/14/95 15:43 Units

Lead(Pb) in Dust

Below detection limit

Location: hallway	Area in Inches
Surface: well	(L x W): 38 x 0.75
Submitter's sample number: 105	Case number: 95-30-066
Sample collected by: J. O'Brien	

Specimen: 27038 Result for 07/14/95 15:43 Units

Lead(Pb) in Dust

Below detection limit

Location: hallway	Area in Inches
Surface: floor	(L x W): 12 x 12
Submitter's sample number: 106	Case number: 95-30-066
Sample collected by: J. O'Brien	

Specimen: 27039 Result for 07/14/95 15:43 Units

Lead(Pb) in Dust 37 ug/sg ft

Location: stairwell	Area in Inches
Surface: floor	(L X W): 12 x 12
Submitter's sample number: 107	Case number: 95-30-066
Sample collected by: J. O'Brien	

* * * * * End of Report * * * * *

