

CITY OF BALTIMORE

WILLIAM DONALD SCHAEFER, Mayor



FIRE DEPARTMENT

Fire Prevention Bureau
Oldtown Fire Station
1100 Hillen Street
Baltimore, Maryland 21202

March 21 85
-/.....19.....

Mr. J. Edwin Myers
United Evangelical Church
Dillon Street and East Avenue
Baltimore, Maryland 21224

Attention is called Violation of Article 9, Fire Prevention Code approved June 28, 1982, as follows:

PREMISES: Dillon Street and East Avenue - United Evangelical Church

CORRECT BY

Article 5, Section F - 503.1

Provide and maintain exit signs and exit directional signs for 2nd, 3rd, and 4th floors in building where the direction of travel to reach the nearest exit out of the building is not readily apparent.

FOURTEEN DAYS

Article 1, Section F - 105.3

Provide and install emergency lighting on premises.

THIRTY DAYS

Article 4, Section F - 402.1

Provide one (1) class 2A fire extinguisher for junior department.

SEVEN DAYS

Article 5, Section F - 504.1

Repair door check on door leading to stairs from Auditorium, Northeast corner of building.

MUST BE CORRECTED BY NUMBER OF DAYS INDICATED.

Inspector Lt. James Thomas
In Office 7:00 - 9:00 A.M.
396 - 5752

Chief of Fire Department

CITY OF BALTIMORE

WILLIAM DONALD SCHAEFER, Mayor



FIRE DEPARTMENT

Fire Prevention Bureau
Oldtown Fire Station
1100 Hillen Street
Baltimore, Maryland 21202

ORDINANCE
No. 278
INFORMATION

March.../..21.....19.85.....

Mr. J. Edwin Myers
United Evangelical Church
Dillon Street and East Avenue
Baltimore, Maryland 21224

Attention is called Violation of Article 9, Fire Prevention Code approved June 28, 1982, as follows:

PREMISES:

CORRECT BY

Article 4, Section F - 406.2.2

Provide additional nozzles over cooking facility in kitchen so same will be completely protected.

THIRTY DAYS

Article 4, Section F - 406.10

Have fixed pipe automatic fire extinguishing system over cooking appliance recharged and serviced.

FOURTEEN DAYS

MUST BE CORRECTED BY NUMBER OF DAYS INDICATED.

Inspector Lt. James Thomas

In Office 7:00 - 9:00 A.M.
396 - 5752

Chief of Fire Department