



State of Maryland
 Department of the Environment
 Hazardous and Solid Waste Management Administration
 2500 Broening Highway, Baltimore, Maryland 21224

CASE # 97-2136 BC

Report of Observations

FACILITY I.D. # _____

Type of Inspection/Observation: ROUTINE Date 6 | 5 | 97

Facility Name: UNITED EVANGELICAL CHURCH 3200 DILTON ST BALTO MD

Remarks: _____

FOLLOW UP VISIT TO CHURCH TO CHECK ON TD-PURGE ABANDONMENT OF (L) UST ESTIMATED AT 1K GALLONS. UPON ARRIVAL FOUND TANK EMPTY AND CLEAN WITH HOLE THROUGH BOTTOM FOR SOIL SAMPLE. SOIL AROUND EXCAVATION CHECKED WITH MICROTIIP METER AFTER THE CALIBRATION AND NEW FILTER INSTALLED. READINGS WERE 47.PPM. SOIL WAS REMOVED APPROXIMATELY 3FT BELOW BOTTOM OF TANK AND CHECKED WITH METER - READING WAS 167.PPM SOIL WILL BE TESTED FOR TPH AND NAPHTHALENE WITH STATE SENT COPY OF ANALYSIS FOR REVIEW. WORK BEING DONE BY AEA ENVIRONMENTAL SERVICES, ON SITE WAS LIEUTENANT EDWARD BELING FIRE DEPT. BALTO CITY. SLURRY CONCRETE WILL BE USED TO BACKFILL TANK TANK ESTIMATED TO BE 42 YRS OLD NO PROBLEMS INDICATED HOLE IN TANK IN AREA OF RILL PIPE.

TIME IN :

TIME OUT

Observer:

[Signature]

Person Interviewed:

[Signature] AEA



MUST BE POSTED
ON PREMISES

CITY OF BALTIMORE FIRE DEPARTMENT

FIRE PREVENTION PERMIT

APPLICATION DATE	06/02/97	DATE ISSUED	06/02/97	EXPIRATION DATE	00/00/00	PERMIT NUMBER	7967	
APPLICANT NAME	UNITED EVANGELICAL CHURCH			ADDRESS	0925 S EAST AVE (21224)		PHONE NUMBER	000-000-0000

THE ABOVE NAMED INDIVIDUAL/BUSINESS HEREBY MAKES APPLICATION TO CONDUCT THE FOLLOWING BUSINESS AT THE ABOVE LOCATION
ABANDON (IN PLACE WITH SLURRY) (1) 1,000 GALLON UNDERGROUND NO. 2 FUEL OIL
TANK



AND FOR THE KEEPING, STORAGE, OCCUPANCY, USE, SALE, HANDLING, OR MANUFACTURE OF THE FOLLOWING:

(STATE QUANTITIES NORMALLY TO BE STORED, HOW STORED, OR USED, GIVING AMOUNTS FOR EACH KIND OR CATEGORY.)

CONTRACTOR: BEST ENVIRONMENTAL SERVICES, INC. (410-636-3700)
REISTERSTOWN, MD., 21136

(CALL 410-396-5752 - 48 HOURS IN ADVANCE TO TANK ABANDONMENT)
CK. NO. 1556

IN ACCORDANCE WITH SECTION 103.0 (PERMITS) AND SECTION(S) F-3201.2/N
OF THE FIRE PREVENTION CODE OF THIS JURISDICTION.

APPLICATION RECEIVED BY FIRE OFFICIAL	DATE	FEE PAID
SAUNDERS, THEODORE G., CAPT.	06/02/97	\$ 125.00

Theodore G. Saunders - Chief of Fire Department

FIRE PREVENTION BUREAU:
414 N. CALVERT ST., BALTIMORE MD. 21202
410-396-5752

Department Of Housing And Community Development
Division Of Construction And Buildings Inspection

No: 81399

THIS WRITTEN INSTRUMENT, WHEN PROPERLY VALIDATED, CONSTITUTES AUTHORITY FOR DOING OR RECEIVING THE THINGS INDICATED BY THE FEES OR CHARGES SHOWN IN THE APPROPRIATE SPACES BELOW. ANY AND ALL THINGS TO BE DONE OR RECEIVED UNDER THIS WRITTEN INSTRUMENT SHALL BE DONE OR RECEIVED IN STRICT COMPLIANCE WITH THE APPLICATION HERETOFOREFILED IN THIS DEPARTMENT FOR THE AUTHORITY CONTAINED HEREIN, INCLUDING ANY AND ALL APPROVED DRAWINGS AND OTHER DATA OR INFORMATION ATTACHED THERETO, AND SUBJECT TO ANY AND ALL LAWS, ORDINANCES, RULES AND REGULATIONS IN EFFECT IN THE CITY OF BALTIMORE AND THE STATE OF MARYLAND. WARNING: IT IS UNLAWFUL TO WORK BETWEEN THE HOURS OF 7:00 PM AND 7:00 AM WITHIN 300 FEET OF A DWELLING.

WARNING: IT IS UNLAWFUL TO CONCEAL ANY WORK UNTIL INSPECTED AND APPROVED BY THIS DEPARTMENT.

WARD	SEC.	BLOCK	LOT	ISSUE DATE	DISTRICT	MINOR PRIVILEGE	PLANS NO.
26	05	6459	033	06/02/97	019		

PROPERTY ADDRESS: 0925 S EAST AVE
KNOWN AS: 3200 DILLON ST
OWNER: UNITED EVANGELICAL CHURCH

ADDR: 3200 DILLON ST

LESSEE:
PRIME
CONTR: A. AND A. ENVIRONMENTAL
PHONE: 410-636-3700

ADDR:

ADDR:

ELECTRICAL CONTRACTOR:

LIC. NO. : M 001200

LIC. NO. : 000000

PLUMBING CONTRACTOR:

LIC. NO. : 000000

GAS FITTER:

LIC. NO. : 000000

HVAC & R CONTR:

LIC. NO. : 000000

WORK COST	COMP. DATE	LAND USE CODES
2,800.00	05/30/98	

ABANDON IN PLACE WITH SLURRY FILL ONE 1000 GALLON UNDERGROUND NO. 2
FUEL OIL TANKS.

A-001-139-260-00-000 PER. INSP.	A-001-131-260-09-000 MISC.	A-001-131-260-09-000 CH. USE	A-001-132-260-01-000 NEW BLDG.	A-001-132-260-02-000 ADDITIONS
A-001-132-260-03-000 ALTERATIONS	A-001-132-260-04-000 REPAIRS	A-001-132-260-05-000 MISC. CONST.	A-001-133-260-00-000 ELECT.	A-001-134-260-01-000 HEAT
A-001-134-260-02-000 REFRIG.	A-001-134-260-03-000 AIR COND.	A-001-134-260-04-000 DISP. TANKS 25.00	A-001-134-260-05-000 FIRE	A-001-134-260-06-000 GAS
A-001-136-260-00-000 ELEVATOR	A-001-135-260-00-000 PLUMBING	A-001-132-260-07-000 S & E CONTROL	A-001-868-570-01-000 CHAPS	A-001-051-150-00-000 TAX 2.00
A-001-132-260-06-000 RAZING				TOTAL FEES 27.00

INSPECTOR'S REPORT OF INSPECTION

DATE	TYPE OF INSPECTION & NOTE	INITIAL	DATE	TYPE OF INSPECTION & NOTE	INITIAL
			COMPLETION DATE	INSPECTOR'S SIGNATURE	

Department Of Housing And Community Development
 DIVISION OF CONSTRUCTION AND BUILDINGS INSPECTION

No: 81399

THIS WRITTEN INSTRUMENT, WHEN PROPERLY VALIDATED, CONSTITUTES AUTHORITY FOR DOING OR RECEIVING THE THINGS INDICATED BY THE FEES OR CHARGES SHOWN IN THE APPROPRIATE SPACES BELOW. ANY AND ALL THINGS TO BE DONE OR RECEIVED UNDER THIS WRITTEN INSTRUMENT SHALL BE DONE OR RECEIVED IN STRICT COMPLIANCE WITH THE APPLICATION HERETOFOREFILED IN THIS DEPARTMENT FOR THE AUTHORITY CONTAINED HEREIN, INCLUDING ANY AND ALL APPROVED DRAWINGS AND OTHER DATA OR INFORMATION ATTACHED THERETO, AND SUBJECT TO ANY AND ALL LAWS, ORDINANCES, RULES AND REGULATIONS IN EFFECT IN THE CITY OF BALTIMORE AND THE STATE OF MARYLAND. WARNING: IT IS UNLAWFUL TO WORK BETWEEN THE HOURS OF 7:00 PM AND 7:00 AM WITHIN 300 FEET OF A DWELLING.

WARNING: IT IS UNLAWFUL TO CONCEAL ANY WORK UNTIL INSPECTED AND APPROVED BY THIS DEPARTMENT.

WARD	SEC.	BLOCK	LOT	ISSUE DATE	DISTRICT	MINOR PRIVILEGE	PLANS NO.
26	05	6459	033	06/02/97	019		

PROPERTY ADDRESS: 0925 S EAST AVE
 KNOWN AS: 3200 DILLON ST
 OWNER: UNITED EVANGELICAL CHURCH

ADDR: 3200 DILLON ST

LESSEE:
 PRIME
 CONTR: A. AND A. ENVIRONMENTAL
 PHONE: 410-636-3700

ADDR:
 ADDR:

LIC. NO. : M 001200
 LIC. NO. : 000000
 LIC. NO. : 000000
 LIC. NO. : 000000
 LIC. NO. : 000000

ELECTRICAL CONTRACTOR:

PLUMBING CONTRACTOR:

GAS FITTER:

HVAC & R CONTR:

WORK COST	COMP. DATE	LAND USE CODES
2,800.00	05/30/98	

ABANDON IN PLACE WITH SLURRY FILL ONE 1000 GALLON UNDERGROUND NO. 2 FUEL OIL TANKS.

A-001-139-260-00-000 PER. INSP.	A-001-131-260-09-000 MISC.	A-001-131-260-09-000 CH. USE	A-001-132-260-01-000 NEW BLDG.	A-001-132-260-02-000 ADDITIONS
A-001-132-260-03-000 ALTERATIONS	A-001-132-260-04-000 REPAIRS	A-001-132-260-05-000 MISC. CONST.	A-001-133-260-00-000 ELECT.	A-001-134-260-01-000 HEAT
A-001-134-260-02-000 REFRIG.	A-001-134-260-03-000 AIR COND.	A-001-134-260-04-000 DISP. TANKS 25.00	A-001-134-260-05-000 FIRE	A-001-134-260-06-000 GAS
A-001-136-260-00-000 ELEVATOR	A-001-135-260-00-000 PLUMBING	A-001-132-260-07-000 S & E CONTROL	A-001-868-570-01-000 CHAPS	A-001-051-150-00-000 TAX 2.00
A-001-132-260-06-000 RAZING				TOTAL FEES 27.00

THE AUTHORITY CONTAINED HEREIN DOES NOT AUTHORIZE THE PERFORMANCE OF ANY WORK IN, ON, UNDER OR OVER ANY STREET, HIGHWAY, ALLEY, SIDEWALK OR ANY OTHER PUBLIC WAY, UNLESS PERMISSION TO DO SO HAS BEEN FIRST SECURED FROM THE PROPER AUTHORITY.

THIS AREA BELOW FOR VALIDATION ONLY

THE AUTHORITY CONTAINED HEREIN MAY NOT BE VALIDLY EXERCISED UNTIL AND AFTER ALL OF THE FEES APPEARING HEREON HAVE BEEN PAID AND EVIDENCE THEREOF APPEARS IN THIS SPACE.



William G. Alar
 DIRECTOR
 CONSTRUCTION AND BUILDINGS
 INSPECTION

#001 FRID M800 BALTO
 0005 JUN 04 1997 10:08AM
 0544 MISC 27.00

PER: CAIN/SE

PURCHASER

American Stone-Mix, Inc.

8320 Bellona Avenue, Towson, Maryland 21204-2086

FLO-ASH[®] SERVICES

410-682-5462

07398

DELIVERY DATE

6/5/97

QUANTITY

5 YD³

SOLD TO

A & A

DELIVERED TO

UNITED METHODIST CHURCH

3200 D. HALL ST.

TRUCK

503

MIX NO.

F-5 Pump

TIME START

TIME COMPLETED

DRIVER

CARVEY

RECEIVED BY

Warren Pinner

PHOTOGRAPHS • 1021 PAULISON AVE • CLIFTON, NJ 07015-1967 • 800-456-7871

PHASE SEPARATION SCIENCE, INC.

Analytical Chemistry Environmental Science

FAX COVER SHEET

FAX TO: Darren Pierce

FROM: John Richardson

PROJECT: United Evangelical Church
925 S. East Ave.


PROJECT#: 447

PAGES FAXED: 3
(including fax cover)

10 June 1997

OFFICES:
6630 BALTIMORE NAT'L PIKE
ROUTE 40 WEST
BALTIMORE, MD 21228
410-747-8770
800-932-9047
FAX 410-788-8723

PHASE SEPARATION SCIENCE, INC.



CERTIFICATE OF ANALYSIS
No. 970605-15 002
A&A Environmental, Inc.
June 10, 1997

Analysis of: Soil Sample
Project: United Evangelical Church
Site Location: 925 S. East Ave.
Project Number: 447
Analysis: Total Petroleum Hydrocarbons by GC


Date Sampled: 06-05-97
Date Received: 06-05-97
Date Extracted: 06-06-97
Date Analyzed: 06-07-97

Sample ID **All results are reported in mg/kg**

#1 5,800 as Diesel Fuel


Routine reporting limits have been set at 10 mg/kg.

The above analysis was performed according to procedures described in the following method(s):
EPA Method 8015A-M: Non-halogenated Semi-Volatile Organics
EPA Method 3550A: Sonication Extraction

Reviewed by: 
Quality Assurance Chemist

OFFICES:
 6630 BALTIMORE NATL PIKE
 ROUTE 40 WEST
 BALTIMORE, MD 21228
 410-747-8770
 800-932-9047
 FAX 410-788-8723

PHASE SEPARATION SCIENCE, INC.



CERTIFICATE OF ANALYSIS
 No. 970605-15 001
 A&A Environmental, Inc.
 June 10, 1997

Analysis of: Soil Sample
 Project: United Evangelical Church
 Site Location: 925 S. East Ave.
 Project Number: 447
 Analysis: Purgeable Aromatics

Date Sampled: 06-05-97
 Date Received: 06-05-97
 Date Analyzed: 06-09-97
 Client Sample ID: #1

Compound

All results are reported in ug/kg

Benzene	NR
Toluene	NR
Ethyl Benzene	NR
Xylene	NR
Methyl-t-butyl Ether	NR
Naphthalene	3,700

d-elevated reporting limits due to sample dilution
 e-estimated value below reporting limits
 Routine reporting limits have been set at 1 ug/kg.
 NR-not requested

USEPA methods recommend that the appearance of detectable levels of the above compounds be confirmed when unfamiliar samples are analyzed.

The above analysis was performed according to procedures described in the following method(s):
 EPA Method 8020-M: Purgeable Aromatics
 EPA Method 5030A: Purge and Trap

Reviewed by: 
 Quality Assurance Chemist

DLLR

STATE OF MARYLAND

DEPARTMENT OF LABOR, LICENSING AND REGULATION

PARRIS N. GLENDENING, Governor
KATHLEEN KENNEDY TOWNSEND, Lt. Governor
JOHN P. O'CONNOR, Secretary

DIVISION OF LABOR AND INDUSTRY
SAFETY INSPECTION UNIT
1100 N. EUTAW STREET - ROOM 300
BALTIMORE, MARYLAND 21201

DIRECT DIAL 410-767-2330

ISSUE DATE: 11/23/99

EXPIRATION DATE: 11/04/01

OWNER:

USER:

UNITED EVANGELICAL CHURCH
3200 DILLION STREET
BALTIMORE MD21224-0000

UNITED EVANGELICAL CHURCH
3200 DILLION STREET
BALTIMORE MD 21224-0000

CERTIFICATE OF BOILER OR PRESSURE VESSEL INSPECTION

THIS IS TO CERTIFY THAT THE BOILER OR PRESSURE VESSEL DESCRIBED HEREON
HAS BEEN INSPECTED AND MAY BE OPERATED AT THE PRESSURE LEVEL INDICATED.

MD REG #: MD094294H

NB # / SERIAL #: 0099999

YEAR: 1196

LOCATION: 3LR 2M

TYPE: CAST IRON

BUILT BY: WEIL MCLAIN

MAX PRESS P.S.I.: 30

E357437

NOTIFY YOUR INSPECTION AGENCY PRIOR TO MAKING ANY WELDED REPAIRS ON THIS OBJECT. THIS CERTIFICATE MAY BE
REVOKED AT ANY TIME FOR FAILURE TO COMPLY WITH APPLICABLE SAFETY LAW AND STANDARDS. A BOILER OR PRESSURE
VESSEL CERTIFICATE MUST BY LAW BE POSTED UNDER GLASS IN A CONSPICUOUS PLACE IN THE ENGINE OR BOILER ROOM.

DLR/DLI/BCRT REV 7/99

Dear Jim:

I reviewed this information with Chas Andrejewski
at Marex before I sent it to the Department of the Environment.

They should issue you a number which you should record
and keep. If they ask for more information, give me a call.

A handwritten signature in cursive script, appearing to read "Fred".



DEPARTMENT OF THE ENVIRONMENT

2500 Broening Highway, Baltimore, Maryland 21224

Area Code 301 • 631-3442

William Donald Schaefer
Governor

Martin W. Walsh, Jr.
Secretary

EFFECTIVE JULY 1, 1990, MARYLAND LAW REQUIRES THAT ALL UNDERGROUND STORAGE TANKS CONTAINING OIL BE REGISTERED WITH THE STATE. THIS NEW LAW ALSO PROHIBITS THE RECEIPT OF OIL INTO UNREGISTERED TANKS.

OIL PRODUCTS INCLUDE: GASOLINE, FUEL OIL, OIL REFUSE, OIL MIXED WITH WASTE, CRUDE OIL, AVIATION FUEL, KEROSENE, DIESEL MOTOR FUEL, AND ASPHALT.

NOTE: OIL INCLUDES ALL GRADES OF HEATING OIL

TANKS THAT ARE EXEMPT FROM THE REGISTRATION CRITERIA ARE: UNDERGROUND STORAGE TANKS OF 1,100 GALLONS OR LESS AT SINGLE FAMILY RESIDENCES OR FARMS FOR PRIVATE USE. HEATING OIL TANKS USED FOR BUSINESS, COMMERCIAL OR INSTITUTIONAL USE MUST BE REGISTERED.

IF YOUR TANKS ARE NOT REGISTERED, YOU MUST SUBMIT A REGISTRATION FORM TO THE MARYLAND DEPARTMENT OF THE ENVIRONMENT, HAZARDOUS AND SOLID WASTE MANAGEMENT ADMINISTRATION, UNDERGROUND STORAGE TANK DIVISION, 2500 BROENING HIGHWAY, BALTIMORE, MARYLAND 21224. YOU MAY OBTAIN A FORM BY TELEPHONING (301) 631-3442 OR BY CONTACTING YOUR OIL DELIVERY COMPANY.

**DEPARTMENT OF THE ENVIRONMENT
HAZARDOUS & SOLID WASTE MANAGEMENT ADMIN.
2500 BROENING HIGHWAY
BALTIMORE, MARYLAND 21224
(301) 631-3442**

Notification is required by Maryland law for all underground tanks that have been used to store regulated substances, and are in the ground as of July 1, 1990, or that are brought into use after July 1, 1990. The information requested is required by Environment Article 4-411. On or before July 1, 1990, the owner, operator, or person in charge of an underground oil storage facility shall register the underground oil storage facility with the Department.

Unless an underground oil storage facility is registered with the Department in accordance with Maryland law, no oil may be sold to or received by the underground oil storage facility.

The primary purpose of this notification program is to locate and evaluate underground tanks that store or have stored petroleum or hazardous substances. It is expected that the information you provide will be based on reasonably available records, or, in the absence of such records, your knowledge, belief or recollection.

Who Must Notify? Maryland law requires that, unless exempted, owners of underground tanks that store regulated substances must notify the State of the existence of their tanks. Owner means -

(a) in the case of an underground storage tank in use on July 1, 1990, or brought into use after that date, any person who owns an underground storage tank used for the storage, use, or dispensing of regulated substances and;

(b) in the case of any underground storage tank in use before July 1, 1990, but no longer in use on that date, any person who owned such tank immediately before the discontinuation of its use.

What Tanks Are Included? Underground storage tank is defined as any one or combination of tanks that (1) is used to contain an accumulation of "regulated substances," and (2) whose volume (including connected underground piping) is 10% or more beneath the ground. Some examples are underground tanks storing: 1. gasoline, heating oil, used oil, or diesel fuel, and 2. industrial solvents, pesticides, herbicides or fumigants.

What Tanks Are Excluded? Tanks removed from the ground prior to July 1, 1990 are not subject to notification. Other tanks excluded from notification are: 1. single family residence and farm tanks of 1,100 gallons or less capacity used for storing regulated substances for noncommercial or personal use; 2. septic tanks; 3. pipeline facilities (including gathering lines) regulated under the Natural Gas Pipeline Safety Act of 1968, or the Hazardous Liquid Pipeline Safety Act of 1979, or which is an intrastate pipeline facility regulated under State laws; 4. surface impoundments, pits, ponds, or lagoons; 5. storm water or waste water collection systems; 6. flow-through process tanks; 7. liquid traps or associated gathering lines directly related to oil or gas production and gathering operations; or 8. storage tanks situated in an underground area (such as a basement, cellar, mineworking, drift, shaft, or tunnel) if the storage tank is situated above the surface of the floor.

What Substances Are Covered? The notification requirements apply to underground storage tanks that contain regulated substances. This includes any substance defined as hazardous in section 101 (14) of the Comprehensive Environmental Response Compensation and Liability Act of 1980 (CERCLA) with the exception of those substances regulated as hazardous waste under Subtitle C of RCRA. It also includes petroleum, e.g. crude oil or any fraction thereof which is liquid at standard conditions of temperature and pressure (60 degrees Fahrenheit and 14.7 pounds per square inch absolute). It also includes heating oil.

Where To Notify? Completed notification forms should be sent to the address given at the top of this page.

When To Notify? 1. Owners of underground storage tanks in use or that have been taken out of operation but still in the ground, must notify by July 1, 1990. 2. Owners who bring underground storage tanks into use after July 1, 1990 must notify prior to bringing the tanks into use.

Penalties: Any owner who knowingly fails to notify or submits false information shall be subject to a civil penalty not to exceed \$1,000 for each tank for which notification is not given or for which false information is submitted.

Please type or print in ink all items except "signature" in Section V. This form must be completed for each location containing underground storage tanks. If more than 5 tanks are owned at this location, photocopy the following pages and staple continuation sheets to this form.

Indicate number of continuation sheets attached _____

FACILITY NUMBER _____
(State Use Only)

I. OWNERSHIP OF TANK(S)

Name: United Evangelical Church
Street: East Ave + D. Hill St
City: Baltimore State: MD Zip: 21224
Phone: 276-0393 County: Baltimore

TYPE OF OWNER

- Federal (GSA facility ID# J2-06864JW)
- State County
- Municipal Public School District
- Private or Corporate Volunteer Fire or Ambulance Company
- Current Former
- Other _____

II. LOCATION OF TANK(S)

Name: East Ave + D. Hill St
Street: United Evangelical Church
City: Baltimore State: MD Zip: 21224
County: Baltimore
Number of tanks at this location: 1

III. CONTACT PERSON AT TANK LOCATION

Name: James Tallaghen
Job Title: Property Chairman
Area Code: 21204 Phone: 276-0393

IV. TYPE OF NOTIFICATION

Check here only if this is an amended or subsequent notification for this location.

NOTE: NOT APPLICABLE TO HEATING OIL TANKS ON-SITE.

I have financial responsibility in accordance with Subpart I of RCRA. Please specify:

Method: _____

Insurer: _____

Policy Number: _____

V. CERTIFICATION

(Read and sign after completing Section VII.)

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate, and complete.

Name: James Tallaghen
(Please Print)

Title: Property Chairman

Signature: James Tallaghen

Date Signed: Dec 12 1990

VI. CERTIFICATION OF COMPLIANCE

(Complete for all new tanks at this location) (All others skip to next page)

The installer has been certified by the Maryland Department of the Environment.

OATH: I certify that the information concerning installation provided is true to the best of my belief and knowledge.

Installer: _____

Date: _____

Certificate Number: MDIC- _____

Position: _____

Company: _____

Address: _____

Release Detection (Mark all that apply)

- Automatic tank gauging.
- Vapor monitoring.
- Groundwater monitoring.
- Interstitial monitoring within a secondary barrier.
- Interstitial monitoring within a secondary containment.
- Automatic line leak detectors.
- Line tightness testing.
- Another method allowed by the Maryland Department of the Environment. Please specify. _____

None

Corrosion Protection

- As specified for coated steel tanks with cathodic protection.
- As specified for coated steel piping with cathodic protection.

Tank Identification Number _____

VII. DESCRIPTION OF UNDERGROUND STORAGE TANKS

	Tank No. 1	Tank No. 2	Tank No. 3	Tank No. 4	Tank No. 5
1. Status of Tank (Mark all that Apply)					
Currently in Use	(1)	()	()	()	()
Temporarily Out of Use	()	()	()	()	()
Permanently Out of Use	()	()	()	()	()
Brought Into Use after 3/15/85	()	()	()	()	()
2. Estimated Age (Years)					
	36	()	()	()	()
3. Estimated Total Capacity (Gallons)					
	1000	()	()	()	()
4. Material of Construction (Mark all that Apply)					
Steel	(X)	()	()	()	()
Concrete	()	()	()	()	()
Fiberglass Reinforced Plastic	()	()	()	()	()
Double Wall	()	()	()	()	()
Unknown	()	()	()	()	()
Other, Please Specify					
5. Internal Protection (Mark all that Apply)					
Interior Lining (e.g. epoxy resins)	()	()	()	()	()
None	()	()	()	()	()
Unknown	(X)	()	()	()	()
Other, Please Specify					
6. External Protection (Mark all that Apply)					
Cathodic Protection	()	()	()	()	()
Coated (e.g. asphaltic/epoxy)	(X)	()	()	()	()
Fiberglass Reinforced Plastic Coated	()	()	()	()	()
None	()	()	()	()	()
Unknown	()	()	()	()	()
Other, Please Specify					
7. Piping (Mark all that Apply)					
Bare Steel	()	()	()	()	()
Galvanized Steel	()	()	()	()	()
Fiberglass Reinforced Plastic	()	()	()	()	()
Cathodically Protected	()	()	()	()	()
Coated/Wrapped	()	()	()	()	()
Unknown	(X)	()	()	()	()
Other, Please Specify					
8. Substance Currently or Last Stored in Greatest Quantity by Volume (Mark all that Apply)					
a. Petroleum					
Diesel	()	()	()	()	()
Kerosene	()	()	()	()	()
Gasoline (including alcohol blends)	()	()	()	()	()
Used Oil	()	()	()	()	()
Heating Oil	(X)	()	()	()	()
Other, Please Specify					
b. Hazardous Substance					
Please Indicate Name of Principal CERCLA Substance _____					
or					
Chemical Abstract Service (CAS) No. _____					
Mark box if tank stores a mixture of substances					
	()	()	()	()	()
c. Unknown					
	()	()	()	()	()
9. Additional information (for tanks permanently taken out of service) (Mark all that Apply)					
a. Estimated date last used (mo/day/yr) <i>BEING USED AT PRESENT</i>					
b. Estimated quantity of substance remaining (gal.) <i>500 gallon</i>					
c. Mark box if tank was filled with inert material (e.g. sand, concrete)					
	()	()	()	()	()
d. Mark box if tank was removed					
	()	()	()	()	()

(410) 636-3700
(800) 404-8037

A & A Environmental Services

Fax: (410) 636-0260

5200 Raynor Avenue

Linthicum Heights, Maryland 21090

Industrial - Commercial - Marine
24 Hour Service

United Evangelical Church
3200 Dillon Street
Baltimore, Maryland 21224

May 20, 1997

RE: UST Abandonment

ATTN: John Price
PH: (410) 282-5519

A & A Environmental Services, Inc. is pleased to present this proposal to complete the following project:

Project Description:

Properly abandon one (1) 1,000 gallon underground storage tank (UST) containing heating oil located at the above stated address.

Scope of Work and Materials:

1. Obtain the required Baltimore City and Fire Department Permits.
2. Schedule the required Maryland Department of the Environment and Fire Department inspections.
3. Saw-cut, break and remove the existing concrete.
4. Hand excavate to tank top and open the top of the UST.
5. Pump-out and properly dispose of the heating oil/water (Non-Hazardous) remaining in the UST. Transfer usable oil to existing tank in the adjacent building.
6. Perform a "Confined Space Entry Permit", enter and clean the interior of the heating oil UST.
7. Collect one (1) soil sample from beneath the UST.
8. Analyze the one (1) soil sample for Total Petroleum Hydrocarbons (T.P.H.) EPA Method 8015A-M, Diesel Range Organics and Naphthalene.
9. Slurry fill the UST with an MDE approved material. Includes pumping of the slurry.
10. Patch area with concrete.
11. Submit the required documentation to the MDE.

The client will be supplied with the following documentation:

- Baltimore City and Fire Department Permits
- Maryland Department of the Environment On-Site Inspection Report
- Non-Hazardous Bill of Lading for the Waste Product/Water Disposal
- Soil Sample Analytical Results
- Slurry Fill Receipts

Project Cost and Payment Terms:

Lump-Sum Cost for the Above-Stated Project: \$ 2,750.00

The Payment Terms Required for this Project: NET 30 DAYS


**This proposal will remain firm for 30 Days.

Statement of Contractor Compliance:

A & A Environmental Services will be responsible for obtaining any required permits and licenses. A & A Environmental Services will comply with all Federal, State and Local regulations. A & A Environmental Services will schedule all required inspections. A & A Environmental Services will notify the acting Utility Location Agency and pay any required fees for this service. A & A Environmental Services has in place, an extensive training and drug screening program.

Should you accept this proposal, please sign and return this document by facsimile or mail to A & A Environmental Services, Inc. Once the signed proposal is received, you will be contacted to promptly schedule this project.

Sincerely,



Randi A. Barra
Manager, UST/AST Division

This Proposal is Accepted By:

UNITED EVANGELICAL CHURCH
(Print Company Name)

JOHN M PRICE
PROPERTY CHAIRMAN
(Print Name and Title)

Signature/Date:

John M Price 5/27/97

FAX NAME: DRUG CITY PHARMACY
FAX NUMBER: 410 288 0644

DATE: 27-MAY-97
TIME: 08:59

<u>DATE</u>	<u>TIME</u>	<u>REMOTE FAX NAME AND NUMBER</u>	<u>DURATION</u>	<u>PG</u>	<u>RESULT</u>	<u>DIAGNOSTIC</u>
27-MAY	08:57 S	1 410 636 0260	0:01:24	2	OK	5531401001A2

S=FAX SENT
I=POLL IN(FAX RECEIVED)
O=POLLED OUT(FAX SENT)

TO PRINT THIS REPORT AUTOMATICALLY, SELECT AUTOMATIC REPORTS IN THE SETTINGS MENU.
TO PRINT MANUALLY, PRESS THE REPORT/SPACE BUTTON, THEN PRESS ENTER.



MARYLAND DEPARTMENT OF THE ENVIRONMENT
2500 Broening Highway • Baltimore, Maryland 21224
(410) 631-3000

Parris N. Glendening
Governor

Jane T. Nishida
Secretary

May 5, 1997

Dear Underground Storage Tank Owner:

The State of Maryland, Department of the Environment is in the process of implementing a new data management system for all underground storage tanks (USTs) in the State. In order to efficiently update this data, your assistance is required.

The Department is requesting that within 30 days of receipt of this notice, you complete one of the new UST notification forms for your facility in Maryland that currently has an UST. Enclosed is a copy of the new UST notification form, an instruction sheet and a printout of what the current data management system has listed for your facility. To ensure that your registration is properly updated, please copy your seven-digit Facility I.D. number for the site listed on your printout onto the new notification form in the top right corner. If you have more than one facility please feel free to make copies of the enclosed form.

If you have any questions, please feel free to call the Office of Resource Management at (410) 631-3433.

Sincerely,

Cynthia Keller, Chief
Office of Resource Management
Oil Control Program

CK:rjm

Enclosures

cc: Richard Collins
Horacio Tablada

Bob Day - [unclear]
[unclear]

(410) 636-3700

Best Environmental Services
Affiliate of
A & A Waste Oil Company, Inc.
P.O. Box 928
Reisterstown, Maryland 21136-0928

FAX:
(410) 636-0260

Make Checks Payable To: Best Environmental Services

INVOICE NO: 0727
INVOICE DATE: 6/06/97

UNITED EVANGELICAL CHURCH
3200 Dillon Street
Baltimore, Maryland 21224

ATTN: John Price

RE: UST Abandonment

On June 05, 1997, A & A Environmental Services / Best Environmental Services properly abandon one (1) 1,000 gallon underground storage tank (UST) containing #2 Heating Oil located at the above stated address.

Lump Sum Cost to complete the
Above-Stated Scope of Work:

\$ 2,750.00

Project Total: \$ 2,750.00

Total Invoice: \$ 2,750.00

OK J.P.

Please Return A Copy of This Invoice With Your Remittance
Invoice Amounts Not Paid Within 30 Days Subject to a Late Charge of 1-1/2% Per Month

(410) 636-3700
(800) 404-8037

A & A Environmental Services

Fax: (410) 636-0260

5200 Raynor Avenue
Linthicum Heights, Maryland 21090

*Industrial - Commercial - Marine
24 Hour Service*

United Evangelical Church
3200 Dillon Street
Baltimore, Maryland 21224

May 20, 1997

RE: UST Abandonment

ATTN: John Price
PH: (410) 282-5519

A & A Environmental Services, Inc. is pleased to present this proposal to complete the following project:

Project Description:

Properly abandon one (1) 1,000 gallon underground storage tank (UST) containing heating oil located at the above stated address.

Scope of Work and Materials:

1. Obtain the required Baltimore City and Fire Department Permits.
2. Schedule the required Maryland Department of the Environment and Fire Department inspections.
3. Saw-cut, break and remove the existing concrete.
4. Hand excavate to tank top and open the top of the UST.
5. Pump-out and properly dispose of the heating oil/water (Non-Hazardous) remaining in the UST. Transfer usable oil to existing tank in the adjacent building.
6. Perform a "Confined Space Entry Permit", enter and clean the interior of the heating oil UST.
7. Collect one (1) soil sample from beneath the UST.
8. Analyze the one (1) soil sample for Total Petroleum Hydrocarbons (T.P.H.) EPA Method 8015A-M, Diesel Range Organics and Naphthalene.
9. Slurry fill the UST with an MDE approved material. Includes pumping of the slurry.
10. Patch area with concrete.
11. Submit the required documentation to the MDE.

The client will be supplied with the following documentation:

- Baltimore City and Fire Department Permits
- Maryland Department of the Environment On-Site Inspection Report
- Non-Hazardous Bill of Lading for the Waste Product/Water Disposal
- Soil Sample Analytical Results
- Slurry Fill Receipts

Project Cost and Payment Terms:

Lump-Sum Cost for the Above-Stated Project: \$ 2,750.00

The Payment Terms Required for this Project: NET 30 DAYS


**This proposal will remain firm for 30 Days.

Statement of Contractor Compliance:

A & A Environmental Services will be responsible for obtaining any required permits and licenses. A & A Environmental Services will comply with all Federal, State and Local regulations. A & A Environmental Services will schedule all required inspections. A & A Environmental Services will notify the acting Utility Location Agency and pay any required fees for this service. A & A Environmental Services has in place, an extensive training and drug screening program.

Should you accept this proposal, please sign and return this document by facsimile or mail to A & A Environmental Services, Inc. Once the signed proposal is received, you will be contacted to promptly schedule this project.

Sincerely,



Randi A. Barra
Manager, UST/AST Division

This Proposal is Accepted By: UNITED EVANGELICAL CHURCH
(Print Company Name)

JOHN M PRICE
PROPERTY CHAIRMAN
(Print Name and Title)

Signature/Date: John M Price 5/27/97

LAST TRANSACTION REPORT FOR HP FAX-700 SERIES VERSION: 01.03

FAX NAME: DRUG CITY PHARMACY
FAX NUMBER: 410 288 0644

DATE: 27-MAY-97
TIME: 08:59

<u>DATE</u>	<u>TIME</u>		<u>REMOTE FAX NAME AND NUMBER</u>	<u>DURATION</u>	<u>PG</u>	<u>RESULT</u>	<u>DIAGNOSTIC</u>
27-MAY	08:57	S	1 410 636 0260	0:01:24	2	OK	5531401001A2

S=FAX SENT
I=POLL IN(FAX RECEIVED)
O=POLLED OUT(FAX SENT)

TO PRINT THIS REPORT AUTOMATICALLY, SELECT AUTOMATIC REPORTS IN THE SETTINGS MENU.
TO PRINT MANUALLY, PRESS THE REPORT/SPACE BUTTON, THEN PRESS ENTER.



(301) 937-8611
1-800 336-8611
Fax # 937-9028
FID 52-1340142

5005 Powder Mill Road
P.O. Box 1467
Beltsville, MD 20704-1467

PROPOSAL JW-P126

United Evangelical Church
3200 Dillon Street
Baltimore, MD 21224
Attn: John Price

May 21, 1997

Phone 410-282-5519
Fax 410-276-0393

SITE: 3200 Dillon Street

PAGE 1 of 2

We propose to fill one (1) 1,000 gallon underground storage tank with sand and clean via confined space entry.

THIS PROPOSAL INCLUDES:

- 1) Permits and inspections.
- 2) Excavation to top of tank.
- 3) Disposal of tank contents up to 100 gallons.
- 4) Tank closure report with one (1) soil sample analyzed for TPH.
- 5) Confined space entry crew to enter and clean the 1,000 gallon underground storage tank.
- 6) Filling of tank with sand.
- 7) Repair of concrete with patch.

UNIT RATES:

- 1) Pumping, transportation and disposal of liquids \$0.50 per gallon and \$75.00 per hour (4 hour minimum) vacuum services.

NOTE: This proposal may be withdrawn by us if not accepted within 60 days.

FOR THE SUM OF: Two Thousand Eight Hundred Twenty-Five and 00/100s \$2,825.00

RESPECTFULLY SUBMITTED BY: James Wells

A handwritten signature in blue ink that reads "James Wells".

ACCEPTANCE OF PROPOSAL - The above prices and attached terms and conditions are satisfactory and are hereby accepted. You are authorized to do the work as specified. Payment will be made as outlined in the terms and conditions.

(Signature)

(Date)

(Printed Name and Title)



(301) 937-8611
1-800 336-8611
Fax # 937-9028
FID 52-1340142

5005 Powder Mill Road
P.O. Box 1467
Beltsville, MD 20704-1467

CLIENT NAME:

United Evangelical Church
John Price

PROJECT SITE:

3300 Dillion St
Baltimore MD

Page 2 of 2

GENERAL CONTRACT TERMS AND CONDITIONS

The attached proposal/contract represents the entire agreement between _____ (hereinafter referred to as the CLIENT) and TRI-COUNTY INDUSTRIES, INC. (herein after referred to as the CONTRACTOR). There are no other contracts either expressed or implied. All work to be performed within EPA, U.S.T., RCRA and NFPA guidelines. All material is guaranteed to be as specified. All work to be completed in a workmanlike manner according to standard practices. Any alteration or deviation from the attached specifications involving extra costs will be executed only upon written orders and will become an extra charge over and above the quoted price. All agreements contingent upon strikes, accidents or delays beyond our control. Owner to carry fire, tornado and other necessary insurance. Our workers are fully covered by workmen's compensation insurance.

It is hereby understood that all work to be performed under this contract is based on information provided by the client to the contractor. This information includes tank sizes and capacities, contents, past uses and any other information regarding the tanks, which the contractor may supply to regulatory agencies including Local, State and Federal Government. Client hereby assumes responsibility for any deviations in this information and accepts responsibility for these deviations. Client further agrees to pay contractor for any deviations including additional backfill materials, samples required and additional residual materials which may have to be removed from the tank(s).

The Terms "Tank Owner, Operator or Generator" are terms assigned to the Client. It is hereby understood that the Client is responsible for the tanks, their contents and any pollution or contamination associated with the tanks. It is further understood that the Contractor's liability is limited to the removal, upgrading or installation of the tanks or any related work. The Contractor carries the required public liability, workers compensation and other related insurance for incidents which are caused by the Contractor, its agents or employees. Contractor assumes no responsibility for pollution, contamination, legal fees or any action regarding the tanks.

UTILITIES: Contractor will have public utilities marked via required utility locating service. Contractor will not be held responsible in the event of a missed marking or failure by the public utility to properly mark the area. Private utilities are the sole responsibility of the Client. Contractor will not be held responsible for the locating, relocation or repair of any private utilities, nor will Contractor be responsible for any claims, injuries or property damage due to damage to private utilities.

RESTORATION: Unless expressly agreed to in the contract, Contractor is responsible for backfill to grade only. Restoration of asphalt, concrete, landscaping or building areas is not included. It is hereby understood that the specified work requires the use of heavy construction equipment and trucks. Damage caused by the use of the equipment in performing the required task is assumed and is the responsibility of the client. Damage to areas by trucks delivering or picking up materials, or equipment is at the risk of the client. Contractor will not be responsible for repair or restoration of these areas unless expressly agreed to and included in the contract documents.

ADDITIONAL BACKFILL: Additional backfill material is that material which is required to fill the excavation over and above the tank void. The material needed to fill the tank void is included in the base bid price, unless specified otherwise. All material will be compactible fill dirt, stone or recycled concrete materials. All overburden and over-excavated material will be utilized as backfill when possible. In the event that the material is unsuitable for compactible backfill, it will be hauled off-site and replaced. The unit price quoted includes transportation, placement and compaction. The basis for payment for additional backfill will be on a per ton price as indicated in the proposal. The quantity can be confirmed by calculating the entire amount required to fill the excavation, less that which is needed to fill the tank void. The tank void space will require 7.5 tons per 1,000 gallons of capacity.

CONTAMINATION: It is hereby understood that any contamination of soil, surface water, groundwater or property is the responsibility of the Client or owner. Contractor will exercise all means necessary to limit contamination where possible through abatement and additional excavation. Contractor will not be held responsible for any site conditions which may exist including, but not limited to high water tables, soil types or compositions, contamination of water wells, plumes or aquifers. The term "Excavation, transportation and disposal of contaminated soil" refers to that which is required by owner, client and/or any applicable regulatory agencies to be hauled off-site to an approved disposal facility. The stated prices are for normal excavation only and do not include removal of rock or any unforeseen excavation hazards. Quantities can be confirmed through verification of weight slips received when disposing of soils. Further, Contractor will not be held responsible for surface or perched water which may enter an open excavation and become contaminated. Should water enter an excavation, the owner or client will pay the contractor for removal/disposal of water at the unit prices outlined in the proposal. If the owner or client elects to backfill the excavation to avoid the possibility of water entering, the owner or client will pay the contractor to backfill and/or re-excavate should it become necessary. In the event that groundwater contamination exists and remediation is not feasible through over-excavation or corrective action, it is the responsibility of the owner or client to perform whatever additional remedial action the governing agencies may require. Additional remedial work may include the installation of groundwater monitoring wells, hydrogeological studies or groundwater treatment systems. Should these become a requirement and the owner or client wishes to employ the services of the contractor, that work will be performed under a separate contract.

PAYMENT TERMS: Payment due 30 days from invoice. A 1.5% service charge will be applicable after 60 days. All actual and reasonable collection charges and legal fees will be added if delinquent. A signed acceptance must be returned.

UNDERGROUND STORAGE TANK REMOVAL CONTRACTORS

This list was prepared by the Maryland Department of the Environment from information known to the Department and available at the time of preparation. The Department makes no claim as to its completeness nor to the quality of work performed. Inclusion on this list is not to be considered an endorsement by the State of Maryland.

81 Tank Testing Co., Inc.
A Division of 81 Equipment
21708 Mt. Aetna Road
Hagerstown, Maryland 21740
301-797-3600

A & A Environmental Services
5200 Raynor Avenue
Linthicum, Maryland 21090
410-636-3700

ABC Tank Removal
117 Lakeshore Drive
Pasadena, Maryland 21122
410-437-2507

Advanced Remediation Services, Inc.
P.O. Box 129
Glenn Dale, Maryland 20769
(301) 464-4180

Aero Oil Company
230 Lincoln Way
New Oxford, Pennsylvania 17350
717-624-4311

A.J. Ellis Construction Co.
5555 Branchville Road
P.O. Box 628
College Park, Maryland 20740
301-474-7100

All-State Boiler Service, Inc.
8508 Arborwood Road
Baltimore, Maryland 21208
410-385-1400
410-486-7732 or 410-486-3955 Night

American Combustion
3520 Bladensburg Road
Brentwood, Maryland 20722
(301) 779-3400

Anderson's Crane Service
P.O. Box 174
Queenstown, Maryland 21658
410-827-8476

ATEC Environmental Consultants
8989 Herrmann Drive
Columbia, Maryland 21045
410-381-0232

Baltimore Industrial Services
554 Nanticoke Court
Baltimore, Maryland 21009
410-832-7071
410-515-2018 FAX

Beauchamp Bros. Construction
1507 Glen Avenue
Salisbury, Maryland 21801
(410) 548-2980 or
(410) 548-3223

Besche Oil Company
P.O. Box 277
Waldorf, Maryland 20604
301-645-7061

Better Buildings, Inc.
625 South Smallwood Street
Baltimore, Maryland 21223-3379
410-945-7733
410-233-1844 FAX

Bevard Tank Service, Inc.
7711 Poplar Hill Lane
Clinton, Maryland 20735
301-868-5868

Biddinger Contracting, Inc.
301 West Furnace Branch Road
Glen Burnie, Maryland 21061-2210
(410) 761-6126

BNC
9003-R Yellow Brick Road
Baltimore, Maryland 21237
(410) 780-4025

Bob's Backhoe Service
Rt. 1, Box 311 Deep Landing Road
Chestertown, Maryland 21620
410-778-2371

*Craig
Childress 410-636-0095
ANN04*

Floyd E. Cline & Sons, Inc.
3434 Brethren Church Road
Myersville, Maryland 21773
301-293-2983
301-293-2349 (Fax)

General Physics Corporation
6700 Alexander Bell Drive
Columbia, Maryland 21046
410-290-2300

Global Equipment
11801 Sunbonnet Lane
Monrovia, Maryland 21770
301-831-3711

GRC Company, The
P.O. Box 1541
White Plains Maryland 20695
301-580-4227
301-743-3084
301-753-9743 FAX

H & H Concrete Construction, Inc.
415 Headquarters Drive, Bay 7
Millersville, Maryland 21108
410-987-8884

Harris Trucking & Excavating, Inc.
4110 West Garrison Avenue
Baltimore, Maryland 21215
410-367-4175
410-367-6234 FAX

Hillis-Carnes Engineering
12011 Guilford Road, Suite 106
Annapolis Junction, Maryland 20701
410-880-4788

Howes Construction Group
6614 Hemlock Point Road
Mt. Airy, Maryland 21771
301-831-3968

Hydrosystems, Inc.
100 Carpenter Drive, Ste 200
Sterling, Virginia 20164
703-471-9580

J & L Vance
3621 Leo Street
Baltimore, Maryland 21226
410-355-0765

Jim Walters Contractors, Inc.
2300 59th Avenue
Tuxedo, Maryland 20785
301-773-0130

Kibler Excavators
3648 Washington Blvd.
Baltimore, Maryland 21227
410-242-9471

L.A. Fritter & Son, Inc.
4908 Creston Street
Tuxedo, Maryland 20781
301-773-7800

**L.A. Pafel Petrol Equipment Srv.**
8560 Contractors Road
Baltimore, Maryland 21237
410-592-3777

L.J. Nadwodny & Sons, Inc.
3501 8th Avenue
Baltimore, Maryland 21226
410-355-3581

Law Engineering
8940A Route 108
Columbia, Maryland 21045
410-992-5900

Ledward Rental Equipment
P.O. Box 368
Oceanville, New Jersey 08231
609-652-0363
410-471-5261

Marcor of Maryland, Inc.
246 Cockeysville Road
Hunt Valley, Maryland 21030
410-785-0001

Maryland Liquid Waste, Inc.
3814 Maple Grove Road
Manchester, Maryland 21102
410-239-8962

Maryland Pump Tank & Electric Co.
2512 Erick Street
Baltimore, Maryland 21230 ✓
410-837-0770

Nutshell Enterprises, Ltd.
4059 Norrisville Road
Jarrettsville, Maryland 21084
410-557-7583

Olde Town Contracting, Inc.
8416 Zug Road
Bowie, Maryland 20715
301-262-3978

Tri-County Industries
P.O. Box 1467
Beltsville, Maryland 20705
800-336-8611

301-937-9028

Van's Construction Co., Inc.
P.O. Box 3306
Fredericksburg, Virginia 22402
(703) 373-7502


Warren Tank Service
P.O. Box 340
Brandywine, Maryland 20613
301-372-6300

Waste-Tron of Maryland, Inc.
3922-Vero Road, Suite M
Baltimore, Maryland 21227
410-536-4200

Whitworth Excavating
12680 Clarksville Pike
Clarksville, Maryland 21029
410-531-5033

Whiteford Construction Co., Inc.
1605 Dooley Road
Whiteford, Maryland 21160
410-879-0563 or 879-4901
Fax. (410) 836-5604

York Service Company, Inc.
P.O. Box 4110
Capitol Heights, Maryland 20791
301-350-4500



Maryland Department of the Environment
 Waste Management Administration
 2500 Broening Highway, Baltimore, Maryland 21224

CASE # 97-2126 BC

Report of Observations

FACILITY I.D. # _____

Type of Inspection/Observation: ROUTINE Date 5/20/97

Facility Name: 3200 DILLON ST BALTO MD

Remarks: _____

VISIT TO ABOVE LOCATION TO DISCUSS WORK TO BE DONE TO ABANDON IN PLACE (1) IF UST. UPON ARRIVAL MET WITH JOHN PRICE FROM THE UNITED EVANGELICAL UNITED CHURCH OF CHRIST. BASED ON THE LOCATION OF THE TANK STATE WILL PERMIT TANK REMAIN IN PLACE WITH PUMP OUT AND CLEAN. ALSO PERFORM SITE ASSESSMENT WITH ONE SOIL SAMPLE BEING REMOVED FROM TWO FEET BELOW TANK BOTTOM. HOLE CAN BE DRILLED THROUGH MIDDLE OF TANK. TEST FOR TPH AND NAPHTHALENES SEND STATE COPY OF TEST RESULTS (LOW LEVEL) NOTIFY STATE PRIOR TO START OF WORK AT SITE.

TIME OUT _____

TIME OUT: _____

Observer: Ret. J. J.

Person Interviewed: John W. Price





MARYLAND DEPARTMENT OF THE ENVIRONMENT
2500 Broening Highway • Baltimore, Maryland 21224
(410) 631-3000

Parris N. Glendening
Governor

Jane T. Nishida
Secretary

July 15, 1996

CERTIFIED MAIL

Randi A. Barra
A & A Environmental Services
5200 Raynor Avenue
Linthicum MD 21090

Dear Mr. Barra:

Congratulations, you have met the requirements for recertification of the State of Maryland's Underground Storage System Installers certificate. Enclosed you will find your certification card **MDIC #96-0747**, which will expire August 1, 1998.

This card must be in your possession at all times during underground storage system installation or repair. Please telephone this office at (410) 631-3433 if there are any questions.

Sincerely,

Edwin C. Weber
Project Manager
Oil Control Program

ECW:yvp

Enclosure

cc: Mr. Richard Collins
Mr. Horacio Tablada

STATE OF MARYLAND CERTIFICATE OF TRAINING

Be It known that,

RANDI A. BARRA

1/31/95

Date

has met the requirements for certification of responsible personnel in erosion and sediment control pursuant to Environment Article § 4-104

Printed on Recycled Paper

No 02704

J.L. Hearn

Director

STATE OF MARYLAND Dept. of The Environment Underground Storage System Installer Certificate

Certificate # MDTC-496-0267
Issued To RANDI A. BARRA
Address 5200 BRANNON AVENUE
TENNESSEE 21090
Expires AUGUST 31, 1998

Waste Management Administration

Richard M. Collins Director

This Card is not transferable

Report Underground Storage System Leaks
TO
Hazardous and Solid Waste Management Administration
631-8442 Office Hours
974-8551 After Hours
A Certified Installer must be present
during the entire process of installation, repair, and
removal of an underground storage system.
This card is presented upon demand of any local, state, or federal inspector.