

**BOILER/FIRED PRESSURE VESSEL - REPORT OF INSPECTION**

**The Hartford Steam Boiler Inspection and Insurance Co.**

**Hartford, Connecticut 06102**

Standard Form For Jurisdictions Operating Under The ASME Code

Policy <b>5600361</b>	Location <b>03052</b>	Designating Number <b>MD094293H</b>
--------------------------	--------------------------	--

1 Date Inspected <b>07/25/2011</b>	Cert Exp Date <b>07/25/2013</b>	Certificate Posted <input checked="" type="radio"/> Yes <input type="radio"/> No	Owner Number	Jurisdiction Number <b>MD094293H</b>	National Board Number
---------------------------------------	------------------------------------	---	--------------	---	-----------------------

Owner Name <b>United Evangelical Church</b>	Nature of Business <b>CHURCHES</b>	Kind Of Inspection <input type="checkbox"/> Internal <input checked="" type="checkbox"/> External	Cert. Inspection <input checked="" type="radio"/> Yes <input type="radio"/> No
--	---------------------------------------	---	---

2 Owner Street Address <b>3200 Dillon St.</b>	Owners City <b>Baltimore</b>	State <b>MD</b>	Zip Code <b>21224</b>
--	---------------------------------	--------------------	--------------------------

Users Name at Object Location <b>UNITED EVANGELICAL CHURCH</b>	Specific Location in Plant <b>BLRM</b>	Object Location - County <b>BALTIM CITY</b>
---	---	--

3 Users Street Address <b>925 S E AVE</b>	Users City <b>BALTIMORE</b>	State <b>MD</b>	Zip Code <b>21224</b>
--	--------------------------------	--------------------	--------------------------

4 Type <input type="radio"/> FT <input type="radio"/> WT <input checked="" type="radio"/> CI <input type="radio"/> Other	Year Built <b>1996</b>	Manufacturer <b>WEIL MCL</b>
---	---------------------------	---------------------------------

5 Use <input type="radio"/> Power <input type="radio"/> Process <input checked="" type="radio"/> Steam <input type="radio"/> HWH <input type="radio"/> HWS <input type="radio"/> Other	STM HEAT	Fuel <b>Natural Gas, Automatic</b>	Method of Firing	Pressure Gage Test <input type="radio"/> Yes <input checked="" type="radio"/> No
---	----------	---------------------------------------	------------------	---

6 Pressure Allowed This inspection: <b>15</b>	Previous Inspection: <b>15</b>	Safety Relief Valves Set At: <b>15</b>	Explain If Pressure Changed
--	--------------------------------	---	-----------------------------

7 Is Condition Of Object Such That a Certificate May Be Issued? <input checked="" type="radio"/> Yes <input type="radio"/> No (If NO. explain fully under conditions)	Hydro Test <input type="radio"/> Yes <input checked="" type="radio"/> No	PSI:	Date: <b>00/00/0000</b>
--	---	------	----------------------------

Conditions:  
**No adverse conditions noted.**  
**Min Relief Capacity: 1053 lb/hr**  
**Total Relief Capacity: 1200 lb/hr**

Requirements:  
**None.**

10 Name and Title of Person To Whom Requirements Were Explained  
**HARVEY JACOB (410) 679-6163**

I hereby Certify this is a true report of my inspection:

Signature of Inspector <i>Matthew Dawson</i> <b>Matthew Dawson</b>	Identification No <b>1252</b>	Employed by <b>The Hartford Steam Boiler Inspection and Insurance Co.</b>	Ident. No
--	----------------------------------	--	-----------